

Bid Document

Bid Details	
Bid End Date/Time	29-08-2022 12:00:00
Bid Opening Date/Time	29-08-2022 12:30:00
Bid Offer Validity (From End Date)	75 (Days)
Ministry/State Name	Ministry Of Education
Department Name	Department Of Higher Education
Organisation Name	National Institute Of Technology (nit)
Office Name	Karnataka, Surathkal, Mangaluru
Total Quantity	30
Item Category	Led Luminaire (For Flood Light)-IS:10322, IS:16107 (Q3)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Time allowed for Technical Clarifications during technical evaluation	2 Days
Evaluation Method	Total value wise evaluation

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

MII Purchase Preference

MII Purchase Preference	No
-------------------------	----

MSE Purchase Preference

MSE Purchase Preference

Yes

1. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY.

Led Luminaire (For Flood Light)-IS:10322, IS:16107 (30 pieces)

Brand Type

Registered Brand

Technical Specifications

* [As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
STANDARDS	LED Luminaire conformity to IS:10322/Part 5/Section 5/2012 latest and IS: 16107 (Part 2/Sec 1):2012 latest	Yes
	LED Rating/System Wattage/Rated Power	150W
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP66
	Warranty for free replacement (in Years)	5
ELECTRICAL EFFICIENCY	Input operating Voltage range and frequency	90 to 300 V olts AC at 50 Hz+/-2 Hz
	Rated voltage	230 V AC 50 Hz
	Total Harmonics Distortion (in %age)	≤ 10
OPTICAL	Colour temperature (+/- 500K)	6500K
	Working life for LED (Minimum 50,000 burning hours as per LM-80 report)	Yes
	Colour Rendering Index(CRI)	≥70
	Optic lense materal (UV stabilised) (Write NA for without optic lense supply)	Poly carbonate lense

Specification	Specification Name	Bid Requirement (Allowed Values)
THERMAL MANAGEMENT	Heat sink should be die-cast aluminium along with sufficient heat sink fins to dissipate heat effectively	Yes
	Junction temperature	< 85 degC
	Operating temperature range	-20 deg C to +50 deg C, -10 deg C to +50 deg C
PROTECTION	The luminaire shall be protected against surges and transients (Internal)	>/=5KV
	The luminaire shall be protected against surges and transients of >/=10KV (External)	Yes
CONSTRUCTIONAL	The Luminaires casing/housing (single piece housing) shall be pressure die casted aluminium alloy with higher thermal conductivity	Yes
	Number of electronic control gear (power supplies)	1 No.
	Length of ISI marked three core wire (shall be provided along with supply of material)	50 cm, 100 cm
REPORTS AND CERTIFICATIONS	LED Make	OSRAM / NICHIA/CREE / SAMSUNG / SEOUL / LUMILED / PHILIPS / EDISON / SYSKA / LUMENMAX / EVERLIGHT / BRIDGELUX / NATIONSTAR / REFOND, Other than OSRAM / NICHIA/CREE / SAMSUNG / SEOUL / LUMILED / PHILIPS / EDISON / SYSKA / LUMENMAX / EVERLIGHT / BRIDGELUX / NATIONSTAR / REFOND

Additional Specification Parameters - Led Luminaire (For Flood Light)-IS:10322, IS:16107 (30 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Driver	In-built
Protections for Short-circuit, overload, over-voltage, Heat-sink	Yes, required.
Housing and Mounting	Housing shall be pressure die cast aluminum alloy with higher thermal conductivity, toughened glass, silicon gasket, corrosion resistant body with bracket, mounting clamp, bolt and nuts.

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Dinesh Kamila	575025,NATIONAL INSTITUTE OF TECHNOLOGY KARNATAKA SURATHKAL SRINIVASANAGAR	30	18

Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

2. Scope of Supply

Scope of supply (Bid price to include all cost components) : Only supply of Goods

3. Certificates

Material Test Certificate Should Be Sent Along with The Supply. The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.

4. Warranty

Successful bidder will have to ensure that adequate number of dedicated technical service personals / engineers are designated / deployed for attending to the Service Request in a time bound manner and for ensuring Timely Servicing / rectification of defects during warranty period, as per Service level agreement indicated in the relevant clause of the bid.

Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization. Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity/restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and/or terms and conditions governing the bid. Any clause incorporated by the Buyer such as demanding Tender Sample, incorporating any clause against the MSME policy and Preference to make in India Policy, mandating any Brand names or Foreign Certification, changing the default time period for Acceptance of material or payment timeline governed by OM of Department of Expenditure shall be null and void and would not be considered part of bid. Further any reference of conditions published on any external site or reference to external documents/clauses shall also be null and void. If any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations. Also, GeM does not permit collection of Tender fee / Auction fee in case of Bids / Forward Auction as the case may be. Any stipulation by the Buyer seeking payment of Tender Fee / Auction fee through ATC clauses would be treated as null and void.

[This Bid is also governed by the General Terms and Conditions](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---Thank You---