NATIONAL INSTITUTE OF TECHNOLOGY KARNATAKA, SURATHKAL

DEPARTMENT OF CAREER DEVELOPMENT CENTRE POST SRINIVASNAGAR, MANGALORE – 575 025 (D K) 2474000. Fax: (0824) 2474033

Phone: (0824) 2474000. E- mail: info@nitk.ac.in

Website: http://www.nitk.ac.in



NOTICE INVITING QUOTATION

Notification. No:12/NITK/CDC/2023-24/A-13

Dated: 17/10/2023

Name of Goods	Air Conditioner
Estimated Amount:	Rs.50,000/-
Time for Supply of item after release of Purchase order	7 Days
Document Download / Sale Start Date	23.11. 2023
Clarification Start Date	23.11.2023
Clarification End Date	30.11.2023
Bid Submission Start Date	23-11-2023
Last Date for submission of bids	07.12.2023 before 5.00 PM
Bid Opening Date	08.12.2023 after 9.00 AM
Address for Submission of bids	Career Development Centre NITK Surathkal



NATIONAL INSTITUTE OF TECHNOLOGY KARNATAKA, SURATHKAL DEPARTMENT OF CAREER DEVELOPMENT CENTRE

POST SRINIVASNAGAR, MANGALORE – 575 025

Phone: (0824) 2474000 E- mail: info@nitk.ac.in Fax: (0824) 2474033 Website: http://www.nitk.ac.in

> Sd/-HOD

Notification. No:12/NITK/CDC/2023-24/A-13

Dated: 17/10/2023

NOTICE INVITING QUOTATION (NIQ)

The National Institute of Technology Karnataka, Surathkal (in short – NITK, Surathkal) is an Institute Of National Importance Under Ministry of Education Govt of India, imparting Technical Education and engaged in Research Activities. It is proposed to procure the items for the departmental academic/research activities.

Sealed Quotations as per the Price Schedule given in this NIQ are invited for the following items subject to the terms and conditions, from the reputed manufacturers or its authorised dealers so as to reach on or before scheduled date and time. The quotations in the firm's Business letter head should be address to the "Director, NITK, Surathkal". The envelope shall be superscribed with the Quotation Notification Number and the Name of the Goods for which quotation is submitted.

Name of Goods	Air Conditioner
Estimated Amount:	Rs.50,000/-
Time for Supply of item after release of Purchase order	7 Days
Document Download / Sale Start Date	23.11. 2023
Clarification Start Date	23.11.2023
Clarification End Date	30.11.2023
Bid Submission Start Date	23-11-2023
Last Date for submission of bids	07.12.2023 before 5.00 PM
Bid Opening Date	08.12.2023 after 9.00 AM

SECTION-1 Terms and Conditions

- 1. The rates should be quoted for preferably FOR destination from supply within India.
- 2. The bidder shall indicate the excise duty exemption for the goods if applicable.
- 3. The rate quoted should be on unit basis. Taxes and other charges should be quoted separately, considering exemptions if any. The rate should be quoted in INR only
- 4. Rate quoted should be inclusive of Testing, commissioning and Installation of equipment and Training.
- 5. Payment: No advance payment will be made. Payment will be made only after the supply of the item in good and satisfactory condition and receipt of performance security by supplier.
- 6. Guarantee/Warrantee period should be specified for the complete period should be specified in section 3 of this tender document.
- 7. Period requirement for the supply and installation of item should be specified in section 3 of this tender document.
- 8. In case of dispute, the matter will be subject to Mangalore Jurisdiction only.

SECTION-2 SCHEDULE OF REQUIREMENTS, SPECIFICATIONS AND ALLIED DETAILS

[To be filled up by the Department / Centre of NITK, Surathkal]

Item(s) Name to be Procured	: Air Conditioner
Brief Specifications of the Item(s) (Attach Additional Sheet if necessary)	: Enclosed in separate sheet
Quantity	: 01
Any other details / requirement	:
Warranty Period required	: 10 Years warranty on Compressor, 5 years on PCB and 1 Year warranty on Product Stabilizer & Installation.
Delivery Schedule expected after placement of Purchase order (in Weeks)	: 1 week

SECTION 3 PRICE SCHEDULE

[To be used by the bidder for submission of the quotation]

1.	Item Name	:
2.	Specifications (Conforming to Schedule of requirements Enclose additional sheets if necessary)	:
3.	Currency and Unit Price	:
4.	Quantity	:
5.	Item Cost (SI No. 3 * SI. No. 4)	:
6.	Taxes and Other Charges(i) Specify the type of taxes and duties in percentages and also in figures.(ii) Specify Other Charges in figures.	:
7.	Warranty Period (Conforming to the Schedule of requirements)	:
8.	Delivery Schedule (Conforming to the Schedule of requirements)	:
9.	Name and address of the Firm for placing purchase order	:
10.	Name and address of Indian authorized agent (in case of imports only)	:
Signa	ture of the Bidder:	
Name	and Designation:	
Busin	ess Address :	
Place	:	Seal of the Bio

Date:

Seal of the Bidder's Firm

<u>SECTION 4</u> CONTRACT FORM [To be provided by the bidder in the business letter head]

- 1. <u>(Name of the Supplier's Firm)</u> hereby abide by the delivery schedule mentioned in this document for supply of the items if the purchase order is awarded.
- 2. The item will be supplied conforming to the specifications stated in this document without any defect and deviations.
- 3. Warranty will be given for the period mentioned in this document and service will be rendered to the satisfaction of NITK, Surathkal during this period.

Signature of the Bidd	er:		
Name	:		
Business Address	:		
Place :		Seal of the Bidder's	s Firm

Date :

Specification:

THE ESTIMATED COST IS INR 50,000/- (as per approval letter).

Further,

- 1. 1.5 Ton 5 Star Split AC
- 2. Capacity : 1.5 Ton
- 3. Star rating : 5 star
- 4. Cooling capacity : 5180 W
- 5. Compressor : Copper
- 6. Operating mode: Cool, Fan , Auto, Dry, sleep, iFeel, ECO, swing, Climate control
- 7. Indore Noise level: High 45 dB, Low 37 dB
- 8. Power requirement: AC 230 V, 50 Hz
- 9. Power Consumption :3620 W
- 10. Dust Filter: Yes
- 11. Remote control: Night Glow button
- 12. Condenser coil: Copper
- 13. Remote control: Yes
- 14. Compressor warranty: 10 year
- 15. PCB : 5 Year
- 16. Product warranty: 1 year
- 17. Suitable stabilizer should be provided along with AC
- 18. The installation charge should be included in the bid.
- 19. Any other charges must also be included in the bid.
- 20. AC unit should have a standard copper tube
- 21. MCB's and AC wiring, fixing to be added in Bid